

Vojenský technický ústav, s.p.
branch VTÚPV
V. Nejedlého 691, 682 03 Vyškov, Czech Republic

CERTIFICATE
N° VTÚPV – 005 / 2013 / ZAHR

Applicant: **CHANGHONG PLASTICS GROUP IMPERIAL PLASTICSCO., LTD**
(4999 Express Way, Xinwu Economic Development Zone) Zhaoqiao
Pioneer Park, Wuhu Machinery Industry Development Zone, Wuhu,
Anhui, China

Product: **Copper Tube Terminals**

Model: SC6-6, SC6-8, SC10-6, SC10-8, SC16-6, SC16-8

Manufacturer: **CHANGHONG PLASTICS GROUP IMPERIAL PLASTICS CO., LTD**
(4999 Express Way, Xinwu Economic Development Zone) Zhaoqiao
Pioneer Park, Wuhu Machinery Industry Development Zone, Wuhu,
Anhui, China

Rating and principal characteristics: Rating Current Max.: 32/32/50/50/63/63 A;
Conductor Area: 6/6/10/10/16/16 mm²

Test results are described in the Test Reports No.:
SCC(12)-203-59-LVD (tests made by China Ceprei (Sichuan) Laboratory)

The sample of tested product conforms with the requirements of the following standards

- EN 61238-1: 2003

This certificate is valid until: **08. 01. 2016**

Vyškov 08. 01. 2013

Tel./Fax: +420 517 303 603
e-mail: milan.bezdek@vtusp.cz
<http://www.vtusp.cz>

M. Bezdek
Milan Bezdek
Certification Head

