

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Circuit-breakers (MCCB)

Name and address of the applicant

LS ELECTRIC Co., Ltd.  
LS Tower, 127 LS-ro, Dongan-gu, Anyang-si, Gyeonggi-Do,  
14119, Republic of Korea

Name and address of the manufacturer

Shanghai Yongji Electrical Co., Ltd.  
No. 2239, South Jinshi Road, Jinshanwei Town,  
Jinshan District, Shanghai City, P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

See page 2

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

BKJ63N

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

210403094SHA-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden**intertek**

Signature:



Henrik Wikström

Date: 01 July, 2021

**Factories**

Shanghai Yongji Electrical Co., Ltd.  
No. 2239, South Jinshi Road, Jinshanwei Town,  
Jinshan District, Shanghai City, P.R. China

Zhejiang Yongji Electrical Co., Ltd.  
No.788, Nanming Road, Lishui Economic and Technological Development Zone, Lishui City,  
Zhejiang Province, P.R. China

**Ratings and principal characteristics**

$U_e = 240V \sim (1P, 1P+N), 415V \sim (2P, 3P, 3P+N, 4P), 50/60Hz$ ;  
 $I_n = 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A$ ;  
Ref. temperature:  $45^\circ C$ ;  
Curve B:  $I_i = 4I_n$ , Curve C:  $I_i = 8I_n$ , Curve D:  $I_i = 12I_n$ ;  
 $I_{cu} = I_{cs} = 6kA$ ;  
Utilization category: A,  $U_{imp} = 4kV, U_i = 500V$ ;  
The neutral pole is identical with phase pole.

Date: 01 July, 2021

Signature: 