

DECLARATION of Conformity

Order No.: MTS/PNZ/E11060613

Holder: Helior Technology Co., Ltd
3/F, Haibin Industrial Park, Xingye Rd., Ano'an, Shenzhen, P.R.
China

Equipment Description: UPS Uninterruptible Power Supply

Model Name: Braver400, Braver500, Braver600, Braver650, Braver800
Braver400L, Braver500L, Braver600L, Braver650L, Braver800L

Technical Data: Input: 230V~, 50Hz, 3A, 600W
Oput: 230V~, 50Hz, 2.3A, 360W

The submitted products have been tested by us with the listed standards and found in compliance with the following European Directives:

The LVD directive 2006/95/EC

EN 62040-1:2008

The tests were performed in normal operation mode. The test results apply only to the particular sample tested and to the specific tests carried out.

This certificate applies specifically to the sample investigated in our test reference number only.

The CE markings as shown below can be affixed on the product after preparation of necessary technical documentation.

Other relevant Directives have to be observed.

July 04, 2011



Mark Wen
For Chief Executives



Most Technology Service Co., Limited

No. 5, 2nd Langshan Road, North District, Hi-tech Industrial Park,
Nanshan, Shenzhen, Guangdong, China
Tel: 86 755 8617 0306 Fax: 86 755 8617 0310