

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection

Name and address of the applicant

MAXGE ELECTRIC TECHNOLOGY CO., LTD.

No.299 East Changhong Road, Wukang Town, Deqing County, 313200 Zhejiang Province, P.R.
China

Name and address of the manufacturer

MAXGE ELECTRIC TECHNOLOGY CO., LTD.

No.299 East Changhong Road, Wukang Town, Deqing County, 313200 Zhejiang Province, P.R.
China

Name and address of the factory

Note: When more than one factory, please report on page 2☐ Additional information on page 2

MAXGE ELECTRIC TECHNOLOGY CO., LTD.

No.299 East Changhong Road, Wukang Town, Deqing County, 313200 Zhejiang Province, P.R.
China

Ratings and principal characteristics

1P, 2P, 3P, 4P

Ue = 230 / 400 V for 1P, 2P, 3P and 4P

50 / 60 Hz

In = 1, 2, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63 A

B and C type

Ics = Icn = Icn1: 6000 A for EPB-63M, 4500 A for EPB-63N, 3000 A for EPB-63S

grid distance "a" = 45 mm

Trademark (if any)

MAXGE

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

EPB-63M, EPB-63N, EPB-63S

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

3312601.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.

Meander 1051, NL-6825 MJ Arnhem, Netherlands

