

# ATTESTATION OF CONFORMITY

Issued to: MAXGE ELECTRIC TECHNOLOGY CO., LTD.  
No.299 East Changhong Road, Wukang Town, Deqing Country  
313200 Zhejiang Province, P.R. China

For the product: Circuit breakers for overcurrent protection

Trade name: MAXGE

Type/Model: EPB-63M, EPB-63N, EPB-63S

Ratings: 1P, 2P, 3P, 4P  
Ue = 230 / 400 V for 1P, 2P, 3P and 4P  
50 / 60 Hz, B and C type  
In = 1, 2, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63 A  
Ics = Icn = Icn1: 6000 A for EPB-63M, 4500 A for EPB-63N, 3000 A for EPB-63S  
Energy limiting class: Class 3 for EPB-63M, Class 1 for EPB-63N and EPB-63S  
Grid distance "a" = 45 mm

Manufactured by: MAXGE ELECTRIC TECHNOLOGY CO., LTD.  
No.299 East Changhong Road, Wukang Town, Deqing County,  
313200 Zhejiang Province, P.R. China

Subject: Type Test

Requirements: EN 60898-1:2003, EN 60898-1:2003/A1:2004, EN 60898-1:2003/A11:2005,  
EN 60898-1:2003/A12:2008, EN 60898-1:2003/A13:2012, IEC 60898-1:2015

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a report no. 3312601.50 issued on 2018-04-04.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 25 April 2018

Number: 3312601.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo  
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.



DEKRA Testing Services (Zhejiang) Co., Ltd.

No. 5, Changjiang Road Great Bridge Industrial Park North Baixiang, Wenzhou, Zhejiang, 325603, P. R. China

T +86577628680 00 F +86577629198 89 www.dekra-certification.com