



CB TEST CERTIFICATE

Ref. Certificate No.

NL-23132

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Switch-disconnector		
Applicant:	ZHEJIANG GACIA ELECTRICAL APPLIANCE CO.,LTD	545# Dongdajie, Baitawang Industrial Zone, Beibaixiang, Yueqing, Zhejiang, 325603	China
Manufacturer:	ZHEJIANG GACIA ELECTRICAL APPLIANCE CO.,LTD	545# Dongdajie, Baitawang Industrial Zone, Beibaixiang, Yueqing, Zhejiang, 325603	China
Factory:	ZHEJIANG GACIA ELECTRICAL APPLIANCE CO.,LTD	545# Dongdajie, Baitawang Industrial Zone, Beibaixiang, Yueqing, Zhejiang, 325603	China
Rating and principal characteristics:	Ue: 400 Vac, Ie: 100 A, Ui: 400 V, Uimp: 6 kV 1P, 2P, 3P, 4P AC-22A Rated conditional short-circuit current: 10 kA		
Trade mark (if any):	GACIA		
Model/Type reference:	DL, PDL, SDL, EDL		
Additional information:	This test certificate is based on CB test certificate NL-15947 dated on 2009-05-13. All tests were performed in 2009.		
Sample of product tested to be in conformity with IEC:	60947-3(ed.3)		
Test Report Ref. No:	W0807020.50 and 3303232.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H.L. Schendstok

Date of issue: 2012-05-15



DEKRA Certification is former KEMA Quality