Zertifikat *Certificate*

TÜVRheinland®

Zertifikat Nr. *Certificate No.*
R 50425812

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*	**Unser Zeichen** *Our Reference*	**Ausstellungsdatum**	*Date of Issue*
X.X.B.	01-DY-50211252 001	16.01.2019	*(day/mo/yr)*

Genehmigungsinhaber *License Holder*
MAXGE ELECTRIC
TECHNOLOGY CO., LTD.
NO. 299 EAST CHANGHONG ROAD
DEQING ECONOMIC ZONE, WUKANG
DEQING, ZHEJIANG 313200
P. R. China

Fertigungsstätte *Manufacturing Plant*
MAXGE ELECTRIC
TECHNOLOGY CO., LTD.
NO. 299 EAST CHANGHONG ROAD
DEQING ECONOMIC ZONE, WUKANG
DEQING, ZHEJIANG 313200
P. R. China

Prüfzeichen *Test Mark*

TÜVRheinland CERTIFIED
Type Approved
Safety
Regular Production Surveillance
www.tuv.com
ID 1419064925

Geprüft nach *Tested acc. to*
EN 61095:2009

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Magnetic Contactor (Electromechanical contactor for household and similar purposes)

Type Designation	:1) EPC1-16-x , EPC1-16-xM 2) EPC1-20-x , EPC1-20-xM 3) EPC1-25-x , EPC1-25-xM x=10,20,02,11,30,22,31,40	8
Number of Poles	: 1/2/3/4 Pole	
Rated Operational Voltage	: 250VAC(1/2P); 400VAC(3/4P)	
Rated Frequency	: 50/60Hz	
Utilization Category	: AC-7a; AC-7b	
Rated Operational Current	: 1)16A for AC-7a;6A for AC-7b 2)20A for AC-7a;7A for AC-7b 3)25A for AC-7a;9A for AC-7b	
Conventional Free Air Thermal Current	: 25A	
Rated Insulation Voltage	: 500V	
Rated Impulse Withstand Voltage	: 4,0kV	
Conditional Short-Circuit Current	: Ir=Iq=3kA	
IP Code	: IP20	

8

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

Zertifizierungsstelle

Jie Zhang

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

10/020 d 04.08 ® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.