



# The Standards Institution of Israel

This is to certify that:

EINet Energy & Power Quality Power Meters

Models: EINet LT/LTE, EINet PFC, EINet VIP

Ratings: 100-240Vac, 50/60Hz, 20VA

Measurement circuits:

Voltage: 0-650Vac,

Max. input voltage: 1000V;

Max. input current: 6A

Manufactured by: Control Applications Ltd.

Address: 2A Habarzel St., Tel Aviv, 0069710, Israel

have been tested by the Standards Institution of Israel and found to comply with the standard requirements of:

- ❖ IEC 62053-22: 2003  
Electricity metering equipment (a.c.) –  
Particular requirements –  
Part 22: Static meters for active energy  
(classes 0,2 S and 0,5 S)

used in conjunction with

- ❖ IEC 62052-11: 2003  
Electricity metering equipment (a.c.) –  
General requirements, tests and test  
conditions – Part 11: Metering  
equipment

Test results are detailed in SII Test Report No.: 9312314454.

Certificate No.: 9312314454

Date of issue: 20/08/2015

Dr. Irina Antonov  
Head of Head of Medical Devices, Lasers  
and Electrical Safety Branch  
Electronics and Telematics Laboratory



CERTIFICATE  
OF  
CONFORMITY

ILAN CARMIT  
Director Industry Division  
The Standards Institution of Israel