



## EU DECLARATION OF CONFORMITY

**IMPORTER:** TOP ELECTRONIC COMPONENTS S.A.  
66 Alkminis Str. 11853 Athens Greece  
Tel.: +30-210-3428690 / 693 Fax.: +30-210-342869  
E-mail: info@topelcom.gr

*We hereby declare that the following described products comply with the appropriate basic safety and health requirements of the Low Voltage Directive 2014/35 EU Article 1. In case of the product not agreed by us this declaration will lose its validity.*

**PRODUCTS:** YSLY, YSLCY, YSLYCY

**APPLICABLE DIRECTIVES :**2014/35/EU LOW VOLTAGE DIRECTIVE , ELECTRICAL EQUIPMENT DESIGNED FOR USE WITHIN CERTAIN VOLTAGE LIMITS

**Fire Test Laboratory**

**Notified Body**  
**Nr: 2184**

**AB-0556-T**

**ERA-22-202**

**10-22**

**CLASSIFICATION OF REACTION TO FIRE**  
**IN ACCORDANCE WITH**  
**EN 13501-6:2018**

**Sponsor** : **TOP ELECTRONIC COMPONENTS SA**  
66 Alkminis str. 118 53, Athens, Greece  
Tel: +30 210 3428690-3

**Product name** : YSLY-JZ – 3x2,5 mm<sup>2</sup> – 8,4 mm

**Report no.** : ERA – 22 – 202

**Issue number** : 1/2

**Date of issue** : 11.10.2022

## 1. INTRODUCTION

This classification report defines the classification assigned to “YSLY-JZ – 3x2,5 mm<sup>2</sup> – 8,4 mm” in accordance with the procedures given in EN 13501-6:2018.

## 2. DETAILS OF CLASSIFIED PRODUCT

### 2.1. General:

YSLY-JZ – 3x2,5 mm<sup>2</sup> – 8,4 mm is defined as a “type of classified product”. Its classification is valid for the following end use application:

EN 50575:2014/A1:2016 - Power, control and communication cables - Cables for general applications in construction works subject to reaction to fire requirements

### 2.2. Description:

YSLY-JZ – 3x2,5 mm<sup>2</sup> – 8,4 mm is fully described in the test reports in support of the classification listed in clause 3.1.

### Tested product types:

| Product Name | Rated voltage [V] | Overall external diameter [mm] | Cross section area [mm <sup>2</sup> ] | Cable structure   |
|--------------|-------------------|--------------------------------|---------------------------------------|---|
| YSLY-JZ      | 300/500           | 8,4                            | 3x2,5                                 | PVC outer sheath, PVC insulation, Stranded tinned wire copper conductor (Class 5)<br>Multicore sheathed (unarmoured)<br>Control cable |

# REACTION TO FIRE CLASSIFICATION REPORT

AB-0556-T

ERA-22-202

10-22

## 3. REPORTS AND RESULTS IN SUPPORT OF CLASSIFICATION

### 3.1. Reports

| Name of sponsor                | Report ref. no. | Test method and date<br>Field of application rules and date                  |
|--------------------------------|-----------------|--|
| TOP ELECTRONIC COMPONENTS S.A. | FTST22835       | EN 60332-1-2:2004<br>EN 60332-1-2:2004/A1:2015<br>EN 60332-1-2:2004/A11:2016 |

### 3.2. Results

| Test method                            | Parameter | Number of test | Results                   |                       |
|--|-----------|----------------|---------------------------|-----------------------|
|  |           |                | Continuous parameter mean | Compliance parameters |
| EN 60332-1-2<br>Flame exposition: 60 s | H (mm)    | 1              | 93                        | (-)                   |
| (-): not applicable                    |           |                |                           |                       |

The table below shows the worst results of the classification parameters:

| Test method         | Parameter | Safety margin | Classification result | Compliance parameters |
|---------------------|-----------|---------------|-----------------------|-----------------------|
| EN 60332-1-2        | H (mm)    | (-)           | 93                    | $\leq 425 (E_{ca})$   |
| (-): not applicable |           |               |                       |                       |

## 4. CLASSIFICATION AND FIELD OF APPLICATION

### 4.1. Reference of classification

This classification has been carried out in accordance with the clauses 9.3 of EN 13501-6:2018

### 4.2. Classification

*YSLY-JZ – 3x2,5 mm<sup>2</sup> – 8,4 mm* in relation to its reaction to fire behaviour is classified:

**E<sub>ca</sub>**

The additional classification in relation to smoke production is:

**not classified**

The additional classification in relation to flaming droplets / particles is:

**not classified**

The additional classification in relation to acidity is:

**not classified**

The format of the reaction to fire classification for *YSLY-JZ – 3x2,5 mm<sup>2</sup> – 8,4 mm* is:

| Fire behaviour  |   | Smoke production |                |   | Flaming droplets |                |   | Acidity |                |
|-----------------|---|------------------|----------------|---|------------------|----------------|---|---------|----------------|
| E <sub>ca</sub> | - | s                | not classified | , | d                | not classified | , | a       | not classified |

**Reaction to fire classification: E<sub>ca</sub>**

### 4.3. Field of application

This classification is valid for the following product:

Parameters as determined in the extended application process according to *CLC/TS 50576:2016*

| Cable                                       | <i>YSLY-JZ – 3x2,5 mm<sup>2</sup></i>            |
|---|--|
| Cable family specified in CLC/TS 50576:2016 | Multicore sheathed (unarmoured)<br>Control cable |
| External diameter [mm]                      | 8,4  |
| Rated voltage [V]                           | 300/500  |
| Core  | Stranded tinned wire copper conductor (Class 5)  |
| Insulation                                  | PVC  |
| Outer sheath                                | PVC  |
| Colour                                      | Indifferent                                      |
| Shape                                       | Circular   |
| Flexibility                                 | Flexible   |
| Manufacturing plant                         | Article 2.2                                      |

The classification is valid for all end use applications.

---

## **5. LIMITATION**

---

### **5.1. Restrictions**

This classification report is valid provided that the technical specifications of product are within the limits in accordance with the field of application clause 4.3.

This classification document does not represent type approval or certification of the product.

The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the 305/2011/EU Construction Products Regulation.

The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (e.g. no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.